

BY-LAW NO. 2005-01

A Village of Doaktown By-Law Respecting Cross Connection and Backflow Prevention for the Doaktown Municipal Water System.

The Council of the Village of Doaktown hereby enacts as follows:

1. CROSS CONNECTIONS


- 1.01 No owner or other person shall connect, cause to be connected, or allow to remain connected, any piping, fixture, fitting, container or appliance, in a manner which, under any circumstances, could allow water, waste water, or any other substance to enter the Village water system.
- 1.02 If a condition is found to exist which in the opinion of the Water and Wastewater System Operator or Councillor-in-Charge is contrary to section 1.01 hereof, the Water and Wastewater System Operator or Councillor-in-Charge may either:
- (1) shut off the service or services, or
 - (2) give notice to the customer to correct the fault within a specific period.
- 1.03 Notwithstanding the foregoing, the Water and Wastewater System Operator or Councillor-in-Charge may permit cross connection control devices to be installed on the customer's water piping at the sources of potential contamination and/or on the water service pipe.
- 1.04 Where, in the opinion of the Water and Wastewater System Operator or Councillor-in-Charge, a high risk of contamination of the potable water system exists, or the potential contaminant is extremely dangerous, water service to a customer shall be provided only on the provision that the customer have installed on the customer's water service pipe a cross connection control device approved by the Water and Wastewater System Operator or Councillor-in-Charge in addition to the cross connection control device installed on the customer's water piping at the source of potential contamination.
- 1.05 (1) Where a cross connection control device is required by the Water and Wastewater System Operator or Councillor-in-Charge, that device shall be tested upon installation, and thereafter annually, or more often if required by the Water and Wastewater System Operator or Councillor-in-Charge, by personnel possessing a valid Cross Connection Control Testers Certificate.

- (2) The Water and Wastewater System Operator or Councillor-in-Charge shall maintain a master list of those individuals in possession of valid Cross Connection Control Testers Certificate and such master list shall be available to the public during business hours.
- 1.06 Should a test show that a cross connection control device is not in good working condition, the Water and Wastewater System Operator or Councillor-in-Charge shall give notice to the customer to make repairs or replace the device within a specified period and if the customer fails to comply with such notice the Water and Wastewater System Operator or Councillor-in-Charge shall shut off the service or services.
- 1.07 The Water and Wastewater System Operator or Councillor-in-Charge may permit the use of a water service for construction purposes for a limited time, provided he is satisfied that adequate provision is made to prevent backflow into the Village water system.
- 1.08 All cross connection control devices shall be installed as recommended by the manufacturer and approved by the Water and Wastewater System Operator or Councillor-in-Charge.
- 1.09 Hose bib vacuum breakers shall be installed on all the threaded wall hydrants and threaded taps that are not otherwise protected from backflow in existing buildings when such buildings require new water service connections or relays, or when such buildings are receiving renovations requiring a plumbing permit.


READ FIRST TIME: February 9, 2005

READ SECOND TIME: February 9, 2005

READ THIRD TIME
AND ENACTED: March 9, 2005



Mayor, Charles E. Stewart



Clerk, Marilyn E. Price